

MOBILE AIRPORT AUTHORITY



**Mobile Airport
Authority**

ADDENDUM 1

February 10, 2020

REQUEST FOR PROPOSALS

Demolition of Existing Aircraft Wash Rack

Brookley Aeroplex (BFM)

Mobile Airport Authority

Mobile, Alabama

A. GENERAL. Please reference receipt of this Addendum on your Bid Form.

B. Submitted request for clarifications:

- a. Q. Remove Existing Pretreatment System Allowance. What is this referring to? Is this a set paid amount for this work that will be paid, or for something additional and partial payment?
 - i. A. Item 1 within the unit pricing is the allowance to remove the existing treatment equipment within the tanks including the controls. The equipment reused and removed by others (the allowance is cost to remove the treatment equipment and controls.
- b. Q. Remove Existing Concrete Pavement (approx. 10" Thick). What about the 6" econo-concrete underneath? Remove also and price in with 10" for 16" total depth of concrete? Underlying Stone and Gravel to remain?
 - i. A. Remove all concrete.
- c. Q. Unclassified or Borrow Excavation (Fill) and topsoil. This is paid by cubic yard. Will measurement be by truck bed measurement or in place? If in place who surveys and pays for survey measurements?
 - i. A. Unit pricing is truck load quantities.
- d. Q. Solid Sod (Bermuda). Can the Contractor offer alternate price for seed and mulch of DOT Spec for permanent seed mix design, or, seasonal grass, Bermuda seed, fertilizer and mulch?
 - i. Change unit pricing to seed and mulch per DOT specs.
- e. Q. Can you send an electronic copy of bid sheet so we can apply our bid numbers? Unit Price and Total columns can be entered by contractors?
 - i. A. See attached; Contractor to verify formulas & calculations.
- f. Q. Disposal of tanks and tank contents: Can we get some info/data on the contents/contaminants we are dealing with?
 - i. A. No contaminants; tanks must go to scrap yard or recycle.
- g. Q. Jobsite Access: Which gate will the contractor be allowed to use for access to job site?



- i. A.
- h. A. Clarification on unknown tanks/utilities: Will any underground tank or utility not specified at pre bid and drawings provided be paid under project contingency?
 - i. A. Yes

(end)