

MOBILE AIRPORT AUTHORITY



Mobile Airport Authority

ADDENDUM 1

April 20, 2020

REQUEST FOR PROPOSALS

SAFRAN Roof Repairs

(#2020-006)

West & East Parapet Wall Membrane & Metal Cladding

1804 8th Street, Mobile, AL

30°38'52.21"N

88° 4'9.34"W

GENERAL. Please reference receipt of this Addendum on your Bid Form.

Submitted request for clarifications:

1. Q. Can bid proposal be email?
 - a. Yes; still comply with other requirements within the RFP. Email proposal to russell@mobairport.com

2. Q. Attendees of pre-bid meeting:
 - a. (answer)
 - Dobson Sheet Metal & Roofing, Inc., Charlie Lammons – 251-479-3755
 - Nations Roof, Tony Schatz – 251.661.1971
 - Thomas Roofing, Kyle Thomas – 251.438.2036
 - Russell Stallings, Mobile Airport Authority – 251-438-7334
 - Rodger Fike, Mobile Airport Authority – 251-438-7334

3. Q. Any additional info on parapet section included in RFP?
 - a. Please comply to assembly as noted with same or equal products. In order to maintain the existing roof warranty, the Mule-Hide membrane must be used on the back of roof parapet.

4. Q. Any information on wall panels?
 - a. Install Metal Wall Panels to meet the following; "RmerWallPan" by Garland Company or equal, 10-year water tightness warranty, 30- year finish warranty. Install wall panels and substrates meeting IBC 15 and 16 wind uplift requirements, Manufacturer shall inspect project weekly and issue acceptance that installation meets all warranty requirements. Provide standard color selected by the Airport.